

**VT DIGI PRO****Weidmüller Interface GmbH & Co. KG**

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com



The main function of the voltage tester is to establish if voltage is present. A 2-pole voltage tester is the only approved testing instrument that fulfils the requirements of work protection regulations.

- with LCD-Display
- acc. to VDE standard,
- high peak voltage strength
- the right tester for every application

**General ordering data**

Version	Testing tools, 2-pole voltage tester type 1152
Order No.	<a href="#">9918870000</a>
Type	VT DIGI PRO
GTIN (EAN)	4032248405756
Qty.	1 pc(s).

Creation date March 12, 2024 4:36:55 PM CET

Catalogue status 09.03.2024 / We reserve the right to make technical changes.

## VT DIGI PRO

Weidmüller Interface GmbH &amp; Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

## Technical data

## Dimensions and weights

Depth	67 mm	Depth (inches)	2.638 inch
Height	33 mm	Height (inches)	1.299 inch
Width	264 mm	Width (inches)	10.394 inch
Net weight	272 g		

## Technical data

Description of article	Voltage tester up to 1000 V / 100 Hz LCD
------------------------	--

## Measuring and testing devices

AC voltage display	1 - 1,000 V	AC voltage measuring range	1 - 1,000 V
Adjustment of display backlighting	automatic	Battery type	1.5 V type AAA battery
Buzzer	Yes	Continuity test	Yes - visual + acoustic
DC voltage display	1 - 1,000 V	DC voltage measuring range	1000 V
Display	LCD digital	Frequency measurement	Yes
Frequency range, max.	400 Hz	Frequency range, min.	16 Hz
HOLD function	Yes	Input resistance, voltage	On operating the double switch $\geq 300 \text{ k}\Omega$
Insulation test	8 kV	Load switchable	Yes
Measuring range category	CAT III 1.000V / CAT IV 600V	Note	Screw-on, thicker test probes
One-handed operation	Yes	Peak voltage resistance	8 kV
Phase sequence display	Yes	Protection degree	IP65
RCD circuit breaker	The selectable load enables conscious triggering of a 30 mA RCD circuit breaker	Rated voltage, max.	1000 V AC/DC
Rated voltage, min.	1 V	Residual-current test	Yes
Resistance measurement	Yes	Test probe illumination	Yes
Test probe protection GS 38	Yes	Tested and approved according to	IEC 61243-3:2014 (DIN EN 61243-3:2015-08)
Working temperature, max.	55 °C	Working temperature, min.	-15 °C

## Classifications

ETIM 6.0	EC000494	ETIM 7.0	EC000494
ETIM 8.0	EC000494	ETIM 9.0	EC000494
ECLASS 9.0	27-20-03-08	ECLASS 9.1	27-20-03-08
ECLASS 10.0	27-20-03-08	ECLASS 11.0	27-20-03-08
ECLASS 12.0	27-20-03-08	ECLASS 13.0	27-20-03-08

## Environmental Product Compliance

REACH SVHC	Lead 7439-92-1
SCIP	b05b5122-6117-4cb0-b28c-df32f921fa36

## Approvals

Approvals



ROHS Conform

Creation date March 12, 2024 4:36:55 PM CET

Catalogue status 09.03.2024 / We reserve the right to make technical changes.

2

**VT DIGI PRO**

**Weidmüller Interface GmbH & Co. KG**  
Klingenbergstraße 26  
D-32758 Detmold  
Germany

[www.weidmueller.com](http://www.weidmueller.com)

**Technical data****Downloads**

Approval/Certificate/Document of Conformity	<a href="#">9918870000_DECLARATION_OF_CONFORMITY.pdf</a>
Product Change Notification	<a href="#">PCN-PW641010-20180410-00-A DE</a> <a href="#">PCN-PW641010-20180410-00-A EN</a>
User Documentation	<a href="#">BANL_manual 2pol Tester</a>
Catalogues	<a href="#">Catalogues in PDF-format</a>
Brochures	

**VT DIGI PRO**

**Weidmüller Interface GmbH & Co. KG**  
 Klingenbergstraße 26  
 D-32758 Detmold  
 Germany

www.weidmueller.com

**Accessories**

**Accessories**

Accessories for testing and measuring equipment



**General ordering data**

Type	2POL TESTER ZUB	
Order No.	<a href="#">2565720000</a>	
GTIN (EAN)	4050118575279	
Qty.	1 pc(s).	
Type	BATTERIE 1,5V MICRO	Version
Order No.	<a href="#">9201310000</a>	Testing tools, Battery
GTIN (EAN)	4032248421121	
Qty.	2 pc(s).	
Type	PRSPSU	
Order No.	<a href="#">1332420000</a>	
GTIN (EAN)	4050118136449	
Qty.	1 pc(s).	
Type	SKAI TASCHE	Version
Order No.	<a href="#">2544760000</a>	Toolbag
GTIN (EAN)	4050118554724	
Qty.	1 pc(s).	