



Main

Range of product	TeSys GV2
Device short name	GV2RT
Product or component type	Circuit breaker
Circuit breaker application	Motor protection Transformer protection
Poles description	3P
Network type	AC
Utilisation category	Category A conforming to IEC 60947-2 AC-3 conforming to IEC 60947-4-1
Network frequency	50/60 Hz conforming to IEC 60947-4-1
Breaking capacity	I _{cu} = 100 kA at 220/230 V AC 50/60 Hz conforming to IEC 60947-2 I _{cu} = 100 kA at 400/415 V AC 50/60 Hz conforming to IEC 60947-2 I _{cu} = 15 kA at 440 V AC 50/60 Hz conforming to IEC 60947-2 I _{cu} = 3 kA at 690 V AC 50/60 Hz conforming to IEC 60947-2 I _{cu} = 10 kA at 500 V AC 50/60 Hz conforming to IEC 60947-2
Thermal protection adjustment range	6...10 A
Trip unit technology	Thermal-magnetic
Magnetic tripping current	200 A

Complementary

Mounting mode	By clips By screws
Mounting support	Rail
Mounting position	Horizontal Vertical
Motor power kW	6.3 kW at 500 V AC 50/60 Hz transformer protection 5 kW at 500 V AC 50/60 Hz transformer protection 5 kW at 440 V AC 50/60 Hz transformer protection 5 kW at 400/415 V AC 50/60 Hz transformer protection 4 kW at 400/415 V AC 50/60 Hz transformer protection 2.5 kW at 230/240 V AC 50/60 Hz transformer protection 7.5 kW at 690 V AC 50/60 Hz motor protection high peak current 5.5 kW at 690 V AC 50/60 Hz motor protection high peak current 5.5 kW at 500 V AC 50/60 Hz motor protection high peak current 4 kW at 500 V AC 50/60 Hz motor protection high peak current 4 kW at 440 V AC 50/60 Hz motor protection high peak current 4 kW at 400/415 V AC 50/60 Hz motor protection high peak current 3 kW at 400/415 V AC 50/60 Hz motor protection high peak current 2.2 kW at 220/230 V AC 50/60 Hz motor protection high peak current 1.5 kW at 220/230 V AC 50/60 Hz motor protection high peak current
Control type	Toggle
[U _e] rated operational voltage	690 V AC 50/60 Hz conforming to IEC 60947-2
[U _i] rated insulation voltage	690 V AC 50/60 Hz conforming to IEC 60947-2
[I _{th}] conventional free air thermal current	10 A conforming to IEC 60947-4-1
[U _{imp}] rated impulse withstand voltage	6 kV conforming to IEC 60947-2
Power dissipation per pole	2.5 W
Mechanical durability	100000 cycles
Electrical durability	100000 cycles for AC-3 at 440 V

The information provided in this documentation contains general descriptions and/or technical characteristics of the performance of the products contained herein. This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications. It is the duty of any such user or integrator to perform the appropriate and complete risk analysis, evaluation and testing of the products with respect to the relevant specific application or use thereof. Neither Schneider Electric Industries SAS nor any of its affiliates or subsidiaries shall be responsible or liable for misuse of the information contained herein.

Operating rate	25 cyc/h
Rated duty	Continuous conforming to IEC 60947-4-1
Connections - terminals	Screw clamp terminals 2 cable(s) 1...4 mm ² - cable stiffness : flexible - with cable end Screw clamp terminals 2 cable(s) 1.5...6 mm ² - cable stiffness : flexible - without cable end Screw clamp terminals 2 cable(s) 1...6 mm ² - cable stiffness : solid
Tightening torque	1.7 N.m - on screw clamp terminals
Suitability for isolation	Yes conforming to IEC 60947-1
Phase failure sensitivity	Yes conforming to IEC 60947-4-1
Height	89 mm
Width	45 mm
Depth	78.5 mm
Product weight	0.35 kg

Environment

Standards	EN 60204 IEC 60947-1 IEC 60947-2 IEC 60947-4-1 NF C 63-120 NF C 63-650 NF C 79-130 UL 508 VDE 0113 VDE 0660 CSA C22.2
Product certifications	ATEX BV CCC CEBEC CSA DNV EZU GL GOST RINA SETI TSE UL LROS
Protective treatment	TH
IP degree of protection	IP20 conforming to IEC 60529
IK degree of protection	IK04
Ambient air temperature for operation	-20...60 °C
Ambient air temperature for storage	-40...80 °C
Fire resistance	960 °C conforming to IEC 60695-2-1
Operating altitude	2000 m

Contractual warranty

Period	18 months
--------	-----------